



Government Of West Bengal
Office Of The Divisional Fire Officer, Hooghly
West Bengal Fire & Emergency Services
G.T. Road, Bose Para, Mahesh-1, Serampore,
Hooghly, Pin :- 712202

Memo no.: IND/WB/FES/20192020/60642

Date: 22-10-2023

From:

Divisional Fire Officer, Hooghly
West Bengal Fire & Emergency Services

To: AINEL COLLEGE OF EDUCATION
VILL AND PO - GOURHATI, PS - ARAMBAGH, DIST - HOOGHLY

Sub: Renewal of Fire Safety Certificate of an existing (G+3) Storied Building Under Group of Educational Building in the Name & Style of " AINEL COLLEGE OF EDUCATION " at L.R Plot No – 8954, 8955, 8961,8970, L.R. Khatian No –5172,4772 , J .L NO – 112, P.O – Gourhati, P.S – Arambagh, Dist – Hooghly, Pin - 712613

This is in reference to your application no. 0125191230200340 dated 16-10-2023 regarding the Renewal of Fire Safety Certificate of an existing (G+3) Storied Building Under Group of Educational Building in the Name & Style of " AINEL COLLEGE OF EDUCATION " at L R Plot No – 8954, 8955, 8961,8970, L.R. Khatian No –5172,4772 , J .L NO – 112, P.O – Gourhati, P.S – Arambagh, Dist – Hooghly, Pin - 712613

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

- 1.Regular checking, testing and maintenance of fire safety installation by a licensee.
- 2.Good house keeping to be maintained.
- 3.Regular checking and maintenance of electrical wiring and installation by a licensee Electricians.
- 4.Regular mock fire drill and evacuation drill should be conducted by participation of all and for this purpose a special crew should be formed.
- 5.Escape & entrance routes should not be obstructed if any way.
- 6.Open flame should not be left unattended.
- 7.Fire license to be obtained from this end for the premises (if any) which attracts sec - 12 of the Fire Service Act.

8 After 3 years a certificate shall have to be obtained from this office about the satisfactory performances of all the fire and life safety installations failing which is shall be revoked as per rule - 18 of the West Bengal Fire Services (Fire Prevention & Fire Safety) Rules - 2003

Signature valid

Digitally signed by PRANJAN
KUMAR GHOSH
Date: 2023.10.22 12:23:06 IST

Divisional Fire Officer, Hooghly
West Bengal Fire & Emergency Services